

Monday, 17 January 2022

[REDACTED]
[REDACTED]

Re: Official Information Act Request – Fire Suppression Systems

Kia ora [REDACTED]

Thank you for your request for information under the Official Information Act 1982.

You asked:

- *Please advise how many of your electrical switch rooms have fire suppression systems*
- *If there is a fire suppression system what type of system, e.g. water sprinklers, gas flood, or other system?*
- *If nothing, then NIL.*

The Hauora Tairāwhiti response is as follows:

Hauora Tairāwhiti has water sprinklers in eight switch rooms.

If you are not satisfied with this response you may contact the Office of the Ombudsmen, phone 0800 802 602.

Please note this response or an edited version of this response may be published on the Hauora Tairāwhiti DHB website. Your personal/identifying information will be redacted from any responses published. If you feel that there are good reasons why your response should not be made publicly available, we will be happy to consider this.

Ngā mihi

Jim Green
Chief Executive
Hauora Tairāwhiti